A 10-10661-10

| REVISIONS |
|---|
| NEW RELEASE PER ECN 16850. |
| REV. A 10/01/07 ADDED NEUTRAL OR GROUNDED SERVICE CONDUCTOR(S) NOTE. ECN 16919. KJK |

SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NO MORE THAN 18,000 AMPS RMS SYMMERTRICAL AT 600 VOLTS OR LESS.




PUMP POWER FAILURE - MOD "N5"




PUMP RUNNING - MOD "N6"




| CONTROL POWER TRANSFORMER PRIMARY WIRING | | |
|---|---|---|
| VOLTAGE | L1 | L2 |
| 200-208 | RED | WHITE |
| 220-240 | ORANGE | WHITE |
| 440-480 | VIOLET | WHITE |

-·—·- DENOTES FIELD SUPPLIED WIRING AND COMPONENTS

– – – – DENOTES FACTORY INSTALLED OPTIONAL EQUIPMENT

TITLE BUL. 10661 JOCKEY PUMP CONTROLLERS
SCHEMATIC DIAGRAM

MADE BY KJK APP'D JMO
DATE 05/23/07

Joslyn Clark
JOSLYN CLARK CONTROLS, LLC
LANCASTER, SC USA 29720-8842

SCALE: 13/16
FILE: 10661-10 REV A

A 10-10661-10
SHEET 1 OF 1

REV. A